


**FERMACELL GYPSUM-FIBREBOARD
(BBA CERTIFICATE No 90/2439)
IRISH BUILDING REGULATIONS STATEMENT**



- THIS STATEMENT RELATES TO FERMACELL GYPSUM-FIBREBOARD AND SETS OUT THE OPINION OF THE BBA ON THE POSITION OF THE PRODUCT UNDER THE BUILDING REGULATIONS IN THE REPUBLIC OF IRELAND.
- It must be read in conjunction with Certificate No 90/2439.
- It will remain valid provided BBA Certificate No 90/2439 is valid.

The Building Regulations 1997/2000 Ireland

In the opinion of the BBA, Fermacell Gypsum-Fibreboard, if used in accordance with the provisions of Certificate No 90/2439, will satisfy or contribute to satisfying the relevant requirements.

Requirement:	B2	Internal fire spread (linings)
Comment:		The boards meet this Requirement for use in all locations. See section 10.2 of this Certificate.
Requirement:	B3	Internal fire spread (structure)
Comment:		The boards will contribute to meeting this Requirement. See section 10.3 of this Certificate.
Requirement:	D1	Materials and workmanship
Comment:		The products are an acceptable material. See section 15 of this Certificate.
Requirement:	E1	Airborne sound (walls)
Comment:		The boards will contribute to meeting this Requirement. See section 13 of this Certificate.

On behalf of the British Board of Agrément



Date of issue: 29th August 2003

Chief Executive